

# National Technical Systems Test Report for Environmental Testing of the Dominion Scanner

#### **Prepared For**

Pro V&V, Inc. | 6705 Odyssey Dr NW Ste C | Huntsville, AL 35806

### **Prepared By**

National Technical Systems | 1601 Dry Creek Drive #2000 | Longmont, CO. 80503 | (303) 776-7249 | www.nts.com

Greg Gagne Technical Writer Robert Polverari ENV Department Manager

This report and the information contained herein represent the results of testing articles/products identified and selected by the client. The tests were performed to specifications and/or procedures approved by the client. National Technical Systems (NTS) makes no representations expressed or implied that such testing fully demonstrates efficiency, performance, reliability, or any other characteristic of the articles being tested, or similar products. This report should not be relied upon as an endorsement or certification by NTS of the equipment tested, nor does it represent any statement whatsoever as to its merchantability or fitness of the test article or similar products for a particular purpose. This document shall not be reproduced except in full without written approval from NTS.



# **Revision History**

Rev.	Description	Issue Date		
0	TR-PR114050	03/20/2020		



### **Table of Contents**

1.0	Introduction							
2.0	eferences	.4						
3.0	roduct Selection and Description							
3.1	Security Classification							
4.0	eneral Test Requirements	.4						
4.1	Test Equipment	.4						
4.2	Notice of Deviation	.4						
5.0	est Descriptions and Results	5						
5.1	Temperature/Power Variation							
5.	<u> </u>							
5.	Test Procedure	6						
5.	Test Datasheets	6						
5.	Test Photographs	.7						
5.								
5.	Test Equipment List	.9						
	List of Tables							
Table 3	1: Product Identification - Equipment Under Test (EUT)	.4						
	2: Dominion Scanner Components							
Table 5	1: Summary of Test Information & Results	5						
Table 5	1: Temperature/Power Variation Test Equipment List	.9						



#### 1.0 Introduction

This document presents the test procedures used and the results obtained during the performance of an Environmental test program. The test program was conducted to assess the ability of the specified Equipment Under Test (EUT) to successfully satisfy the requirements listed in Section 2.0.

#### 2.0 References

The following references listed below form a part of this document to the extent specified herein.

- Pro V&V, Inc. Purchase Order(s) 2020-002, dated 02/24/2020
- National Technical Systems (NTS) Quote(s) OP0544127, dated 02/21/2020
- NTS Corporate Quality Policy Manual, Revision 9, dated 9/20/2018
- ISO/IEC 17025:2017(E) General Requirements for the Competence of Testing and Calibration Laboratories, dated 11/1/2017
- Test Specification: MIL STD 810

#### 3.0 Product Selection and Description

Pro V&V, Inc. selected and provided the test sample(s) to be used as the Equipment Under Test. Details below:

**Table 3.0-1: Product Identification - Equipment Under Test (EUT)** 

Item	Qty.	Name/Description	Part Number	Serial Number		
1	1	Dominion Scanner	Dominion Scanner	See Table 3.0-2		

**Table 3.0-2: Dominion Scanner Components** 

	Tubic 210 21 20 minor Scanner Components									
	Dominion Scanner									
Qty	Part Name	Serial Number								
1	Cannon ImageFORMULA	3149C002	JF302075							
1	Cannon ImageFORMULA	3149C002	JF302076							
1	Cannon ImageFORMULA	3149C002	JF302078							
1	Dell Optiplex 3050	N/A	1F6CH02							
1	Dell Optiplex 3050	N/A	1F8FHQ2							

### 3.1 Security Classification

Non-classified

#### 4.0 General Test Requirements

#### 4.1 Test Equipment

NTS-provided equipment is calibrated according to ISO/IEC 17025:2017(E) and calibration is traceable to the National Institute of Standards and Technology (NIST). Calibration records are maintained on file at NTS.

#### 4.2 Notice of Deviation

In accordance with NTS' quality procedures, when the EUT is observed to exceed or display susceptibility, a Notice of Deviation (NOD) document is generated by the technician performing the test. This NOD documents the requirement, how the EUT deviated from the requirement, and allows room for resolution of the deviation.

This document is reviewed and approved by the NTS Program Manager or Engineer and the NTS Quality Assurance Representative, and then forwarded to the customer contact. Once mitigated (or passed over), the steps taken to correct the deviation (or simply instruction from the customer to continue testing) are recorded in the NOD and a copy of the NOD is integrated into the body of the report, in the appropriate location.



# 5.0 Test Descriptions and Results

Table 5.0-1: Summary of Test Information & Results

Section	Test Specification		Test Facility	Test Date	Part #	Serial #	Test Result*
5.1	Temperature/Power	MIL STD 810	Longmont	03/09/2020 -	Dominion	See Table	N/A
	Variation		-	03/12/2020	Scanner	3.0-2	

<sup>\*</sup>The decision rule used to state compliance is in accordance with the test specification used for testing.



# 5.1 Temperature/Power Variation

# 5.1.1 Test Result

N/A

# **5.1.2** Test Procedure


See below.

# **5.1.3** Test Datasheets

Start Dat	e: 03/09	/20 End Date: 03/12/20 <b>MJO N</b>	o: PR114050			
Customer	: Pro V&	V (Dominion)  Test Performed: Temperature Power Variation Test	Test By: KM			
Part Name: Scanner's Qty-3, PC's Qty- 2 Serial No & Name: See UUT Details Sheet Customer W						
Page	e 1 of 1		Oc to +35c vits to 129vits			
Date	Time	Remarks	Initials			
03/09/20	08:25	Set VAC to 117vlts & ramp to +10c	RSP			
03/09/20	08:45	Start dwell at 117vlts & +10c for 4hrs	RSP			
03/09/20	12:45	Lower VAC to 105vlts & dwell for 4hrs	CL			
03/09/20	16:45	Raise VAC to 129vlts & dwell for 4hrs	KM			
03/09/20	20:45	Lower VAC to 117vlts & Raise temperature to +35c & dwell for 4hrs	KM			
03/10/20	00:45	Lower VAC to 105vlts & dwell for 4hrs	KM			
03/10/20	04:45	Raise VAC to 129vlts & dwell for 4hrs	KM			
03/10/20	08:45	Lower VAC to 117vlts & Lower temperature to +10c & dwell for 4hrs	CL			
03/10/20	12:45	Lower VAC to 105vlts & dwell for 4hrs	CL			
03/10/20	16:45	Raise VAC to 129vlts & dwell for 4hrs	KM			
03/10/20	20:45	Lower VAC to 117vlts & Raise temperature to +35c & dwell for 4hrs	KM			
03/11/20	00:45	Lower VAC to 105vlts & dwell for 4hrs	KM			
03/11/20	04:45	Raise VAC to 129vlts & dwell for 4hrs	KM			
03/11/20	08:45	Lower VAC to 117vlts & ramp to +23c ambient	CL			
03/11/20	08:45	Temperature and power variation portion of test has completed	KM			
03/11/20	08:45	Test will continue to run at +23c ambient for another 37hrs	KM			
03/12/20	21:30	All Testing complete for a total of 85hrs	KM			
		Note: All test pass or fail determinations decided by Pro V&V Inc.				




# 5.1.4 Test Photographs







# 5.1.5 Test Data





# 5.1.6 Test Equipment List

**Table 5.1-1: Temperature/Power Variation Test Equipment List** 

Asset	Manufacturer	Description	M/N	S/N	Range	Start Date	End Date	Last Calibra-	Cal Interval	Cal Due	Notes
Number								tion	(Months)		
WC061559	StorageTek	Temp/Hum	N/A			03/09/2020	03/13/2020	09/19/2019	12	09/19/2020	
		chamber, CH 59									
WC061560	Watlow	TEMPERA-	F4	6165	Multi /	03/09/2020	03/13/2020	09/19/2019	12	09/19/2020	
		TURE CON-			Mfg						
		TROLLER									
WC061561	Honeywell	CHART RE-	DR45A	'0350Y3	Multi /	03/09/2020	03/13/2020	09/19/2019	12	09/19/2020	
		CORDER	T	613409	Mfg						
				00004							

**Calibration Abbreviations** 

CAL: Calibration

NCR: No Calibration Required



**End of Report**