



---

Test Report of  
Full Compliance Immunity Testing  
Performed on the ClearCast Precinct  
Tabulator

Issue Date: 24 September 2018

---

Prepared for: **Pro V&V**  
700 Boulevard South  
Suite 102  
Huntsville, AL 35802


Prepared by: **National Technical Systems**  
NTS Longmont  
1736 Vista View Drive  
Longmont, Colorado 80504



Certificate Number: 0214.43

*This report and the information contained herein represents the results of testing of only those articles/products identified in this document and selected by the client. The tests were performed to specifications and/or procedures approved by the client. National Technical Systems ("NTS") makes no representations expressed or implied that such testing fully demonstrates efficiency, performance, reliability, or any other characteristic of the articles being tested, or similar products. This report should not be relied upon as an endorsement or certification by NTS of the equipment tested, nor does it present any statement whatsoever as to the merchantability or fitness of the test article or similar products for a particular purpose. This document shall not be reproduced except in full without written approval from NTS.*

**SIGNATURES**

Prepared by:  \_\_\_\_\_ Date: 24 September 2018  
Technical Writer, Greg Gagne

Reviewed by:  \_\_\_\_\_ Date: 25 September 2018  
Technical Reviewer, John Tate

**REVISIONS**

<b>Revision</b>	<b>Reason for Revision</b>	<b>Date</b>
NR	Initial Release	

## Table of Contents

1.0	ADMINISTRATIVE DATA .....	7
1.1	PURPOSE OF TESTS.....	7
1.2	DESCRIPTION OF TEST ITEM.....	7
1.3	MANUFACTURER.....	7
1.4	REFERENCE DOCUMENTS.....	7
1.5	TEST RESULTS COMPLIANCE LEVELS.....	8
1.6	QUANTITY OF ITEMS TESTED.....	10
1.7	SECURITY CLASSIFICATION .....	10
1.8	TESTS CONDUCTED BY.....	10
1.9	DISPOSITION OF TEST ITEMS.....	10
1.10	TEST ENVIRONMENT .....	10
1.10.1	IMMUNITY TEST SITE .....	10
1.10.2	MEASUREMENT UNCERTAINTY .....	11
1.11	TEST APPARATUS.....	12
1.12	SOURCE INSPECTION.....	12
1.13	PURCHASE ORDER NUMBER .....	12
2.0	TEST RESULTS SUMMARY .....	13
3.0	ELECTROSTATIC DISCHARGE TEST .....	14
3.1	REFERENCES .....	14
3.2	SERIAL NUMBERS .....	14
3.3	TEST PROCEDURE.....	14
3.4	SPECIAL CONFIGURATIONS .....	14
3.5	TEST RESULTS.....	14
4.0	RADIATED RF IMMUNITY TEST .....	15
4.1	REFERENCES .....	15
4.2	SERIAL NUMBERS .....	15

4.3	TEST PROCEDURE.....	15
4.4	SPECIAL CONFIGURATIONS .....	15
4.5	TEST RESULTS.....	15
5.0	ELECTRICAL FAST TRANSIENT/BURST TEST .....	16
5.1	REFERENCES.....	16
5.2	SERIAL NUMBERS.....	16
5.3	TEST PROCEDURE.....	16
5.4	SPECIAL CONFIGURATIONS .....	16
5.5	TEST RESULTS.....	16
6.0	SURGE IMMUNITY TEST .....	17
6.1	REFERENCES.....	17
6.2	SERIAL NUMBERS.....	17
6.3	TEST PROCEDURE.....	17
6.4	SPECIAL CONFIGURATIONS .....	17
6.5	TEST RESULTS.....	17
7.0	CONDUCTED RF IMMUNITY TEST .....	18
7.1	REFERENCES.....	18
7.2	SERIAL NUMBERS.....	18
7.3	TEST PROCEDURE.....	18
7.4	SPECIAL CONFIGURATIONS .....	18
7.5	TEST RESULTS.....	18
8.0	POWER FREQUENCY H-FIELD IMMUNITY TEST .....	19
8.1	REFERENCES.....	19
8.2	SERIAL NUMBERS.....	19
8.3	TEST PROCEDURE.....	19
8.4	SPECIAL CONFIGURATIONS .....	19
8.5	TEST RESULTS.....	19
9.0	VOLTAGE DIPS AND INTERRUPTS TEST .....	20
9.1	REFERENCES.....	20

9.2	SERIAL NUMBERS .....	20
9.3	TEST PROCEDURE .....	20
9.4	SPECIAL CONFIGURATIONS .....	20
9.5	TEST RESULTS .....	20
	APPENDIX A: ELECTROSTATIC DISCHARGE TEST DATA.....	21
	APPENDIX B: RADIATED RF IMMUNITY TEST DATA.....	29
	APPENDIX C: ELECTRICAL FAST TRANSIENT/BURST TEST DATA.....	36
	APPENDIX D: SURGE IMMUNITY TEST DATA.....	41
	APPENDIX E: CONDUCTED RF IMMUNITY TEST DATA .....	48
	APPENDIX F: POWER FREQUENCY H-FIELD TEST DATA.....	53
	APPENDIX G: VOLTAGE DIPS AND INTERRUPTS TEST DATA .....	60
	APPENDIX H: PRODUCT DATA SHEET.....	65
	APPENDIX I: TEST LOG.....	69
	APPENDIX J: LABORATORY ACCREDITATIONS.....	78
	END OF REPORT .....	84

## 1.0 ADMINISTRATIVE DATA

### 1.1 PURPOSE OF TESTS

This report documents the test efforts performed on the ClearCast Precinct Tabulator to verify compliance to IEC 60601-1-2: 4<sup>th</sup> Ed., 2014-02 Medical Electrical Equipment - Part 1-2: General Requirements for Basic Safety and Essential Performance - Collateral Standard: Electromagnetic Disturbances - Requirements and Tests. This was a formal qualification test and was conducted from 06-12 September 2018.

The normative references of this standard define the test methods used for the immunity testing. These standards are contained in Table 1-1.

### 1.2 DESCRIPTION OF TEST ITEM

The Unit Under Test (UUT) is a precinct tabulator, designed for use in voting during elections.

### 1.3 MANUFACTURER

Clear Ballot Group  
700 Boulevard South  
Suite 102  
Huntsville, AL 35802

### 1.4 REFERENCE DOCUMENTS

1. Pro V&V SOW
2. ISO 17025:2005

The standards applied to this product were IEC 60601-1-2: 4<sup>th</sup> Ed., 2014-02. This is the collateral for Medical Electrical Equipment. The dated references outlined in Table 1 defines the test methods used for the immunity testing. Performance criteria for all immunity testing were derived from IEC 60601-1-2, 4<sup>th</sup> Ed., 2014-02, Table 3.

**Table 1-1: (IEC Standards)**

<b>Requirement</b>	<b>Specification</b>	<b>Test Method</b>
IEC 60601-1- 2, 4 <sup>th</sup> Ed. (2014-02), Medical Electrical Equipment - Part 1-2: General Requirements For Basic Safety and Essential Performance - Collateral Standard: Electromagnetic disturbances - Requirements and Tests	Electrostatic Discharge	IEC 61000-4-2: 2008
	Radiated RF Immunity	IEC 61000-4-3: 2006 + A1: 2007 +A2: 2010
	Electrical Fast Transient/Burst	IEC 61000-4-4: 2012
	Surge Immunity	IEC 61000-4-5: 2005
	Conducted RF Immunity	IEC 61000-4-6: 2013
	Power Frequency H-field	IEC 61000-4-8: 2009
	Voltage Dips, Interrupts	IEC 61000-4-11: 2004

#### 1.5 TEST RESULTS COMPLIANCE LEVELS

Compliance levels to the immunity levels specified in these standards are summarized in Table 1-2.



**Table 1-2 (Professional Healthcare Environment)**

<b>Immunity Test</b>	<b>IEC 60601, 4<sup>th</sup> Edition Test Level</b>	<b>Compliance Level</b>
Electrostatic Discharge	$\pm 8$ kV Contact, HCP & VCP $\pm 2$ kV, $\pm 4$ kV, $\pm 8$ kV, $\pm 15$ kV Air	$\pm 8$ kV Contact, HCP & VCP $\pm 2$ kV, $\pm 4$ kV, $\pm 8$ kV, $\pm 15$ kV Air
Radiated RF Immunity	80 MHz - 2.7 GHz, 3 V/m, 80% 1 kHz AM	80 MHz - 2.7 GHz, 3 V/m, 80% 1 kHz AM
Prox. Fields from RF Wireless	Reference IEC 60601-1-2, 4 <sup>th</sup> Edition, Section 8.10, Table 9	Reference IEC 60601-1-2, 4 <sup>th</sup> Edition, Section 8.10, Table 9
EFT/Burst	$\pm 2$ kV (100 kHz rep rate) AC mains $\pm 1$ kV (100 kHz rep rate) I/O > 3 m	$\pm 2$ kV (100 kHz rep rate) AC mains $\pm 1$ kV (100 kHz rep rate) I/O > 3 m
Surge Immunity	$\pm 0.5$ kV & $\pm 1$ kV line-line, AC mains $\pm 0.5$ kV, $\pm 1$ kV, $\pm 2$ kV line-ground, AC mains	$\pm 0.5$ kV & $\pm 1$ kV line-line, AC mains $\pm 0.5$ kV, $\pm 1$ kV, $\pm 2$ kV line-ground, AC mains
Conducted RF Immunity	150 kHz to 80 MHz, 3 Vrms, 80% 1 kHz AM, power and I/O 6 Vrms (+modulation) for ISM frequencies	150 kHz to 80 MHz, 3 Vrms, 80% 1 kHz AM, power and I/O 6 Vrms (+modulation) for ISM frequencies
Power Frequency H-field Immunity	50 and 60 Hz, 30 A/m, x-, y-, and z-axes	50 and 60 Hz, 30 A/m, x-, y-, and z-axes
Voltage Dips and Interrupts	100% reduction for 0.5 cycles (at 0°, 45°, 90°, 135°, 180°, 225°, 270° and 315°) 100% reduction for 1.0 cycle (at 0°) 30% reduction for 25/30 cycles (at 0°) 100% reduction for 250/300 cycles (at 0°)	100% reduction for 0.5 cycles (at 0°, 45°, 90°, 135°, 180°, 225°, 270° and 315°) 100% reduction for 1.0 cycle (at 0°) 30% reduction for 25/30 cycles (at 0°) 100% reduction for 250/300 cycles (at 0°)

## 1.6 QUANTITY OF ITEMS TESTED

Quantity	Test Item Description	Model Number	Serial Number
1	ClearCast Precinct Tabulator	Model 2, Version A	Unit 1

## 1.7 SECURITY CLASSIFICATION

Unclassified

## 1.8 TESTS CONDUCTED BY

National Technical Systems  
NTS Longmont  
1736 Vista View Drive  
Longmont, Colorado 80504

## 1.9 DISPOSITION OF TEST ITEMS

Returned to:

Pro V&V  
700 Boulevard South  
Suite 102  
Huntsville, AL 35802

## 1.10 TEST ENVIRONMENT

### 1.10.1 Immunity Test Site

The immunity testing was performed at NTS's test facility in Longmont, Colorado. The radiated field immunity testing was performed in a ferrite lined, shielded enclosure. The enclosure is 10' high x 12' wide x 20' long in size and meets the field uniformity requirements of IEC 61000-4-3. The size of the chamber allows 2-meter separation between the antenna and the UUT.

From 80 MHz to 1 GHz, field uniformity deviation for NTS's completely anechoic lined chamber (CALC) is a maximum of 7.4 dB for three frequencies for vertical polarization (1.1% of all test frequencies) and 7.3 dB for two frequencies for horizontal polarization (0.8% of all test frequencies). This is allowed by IEC 61000-4-3, as follows:

**"In the frequency range up to 1 GHz, a tolerance greater than+ 6 dB, up to +10 dB, but not less than -0 dB is allowed for a maximum of 3% of the test**

**frequencies, provided that the actual tolerance is stated in the test report.”**  
 (Ref. IEC 61000-4-3, Ed. 3.2 (2010), Section 6.2)

All other immunity testing was performed on a ground reference plane measuring 3.05 m by 3.05 m, or 9.3 m<sup>2</sup>. The ground plane was made of 90 mil steel and extended beyond the UUT by 0.5 meters and all sides. It was bonded to the protective earth ground of the test facility and complied with all applicable standards.

### 1.10.2 Measurement Uncertainty

The measurement uncertainty for NTS’s immunity test facility complies with the requirements defined in CISPR 16. The complete calculations of measurement uncertainty is contained in a memo, which is available upon request. However, a summary of NTS’s measurement uncertainty is given in Table 1-3.

**Table 1-3**

Test	Measurement Uncertainty	Reference
Electrostatic Discharge	Contact Voltage: 1.9% Risetime: 60 ps Peak Current: 2.8% 30 ns Current: 3.8% 60 ns Current: 9% Indicated Voltage: 1.9%	Accredited Calibration Data Sheet
Radiated RF Immunity	V-pole: 1.2 dB H-pole: 0.7 dB	Worksheets located at H:\Calibration\Measurement Uncertainty
Electrical Fast Transient	Voltage: 0.01 kV Risetime: 0.45 nsec Pulse Width: 1.08 nsec	
Surge Immunity	O.C. Voltage: 0.01 kV Risetime: 0.1 usec Pulse Width: 1.76 usec S. C. Current: 0.91 A Risetime: 0.08 usec Pulse Width: 0.15 usec	
Conducted RF Immunity	0.24 dB	
Power Frequency H-field Immunity	0.87 dB	
Voltage Dips & Interruptions	Voltage: 10.38 Volts Duration: 0.23 msec	

### 1.11 TEST APPARATUS

The instrumentation used in the performance of these tests is periodically calibrated and standardized within manufacturer's rated accuracies and are traceable to the National Institute of Standards and Technology. The calibration procedures and practices are in accordance with ISO 17025:2005. Certification of calibration is on file subject to inspection by authorized personnel.

### 1.12 SOURCE INSPECTION

NTS QA

### 1.13 PURCHASE ORDER NUMBER

2018-010

**2.0 TEST RESULTS SUMMARY****Table 2-1: Summary of Test Results**

<b>Test</b>	<b>Specification</b>	<b>Test Dates</b>	<b>Results</b>
Electrostatic Discharge	IEC 61000-4-2	12 September 2018	Complies
Radiated RF Immunity	IEC 61000-4-3	06 September 2018	Complies
Electrical Fast Transient/Burst	IEC 61000-4-4	10 September 2018	Complies
Surge Immunity	IEC 61000-4-5	11 September 2018	Complies
Conducted RF Immunity	IEC 61000-4-6	10 September 2018	Complies
Power H-Field Immunity	IEC 61000-4-8	11 September 2018	Complies
Voltage Dips and Interrupts	IEC 61000-4-11	10 September 2018	Complies

### 3.0 ELECTROSTATIC DISCHARGE TEST

#### 3.1 REFERENCES

IEC 61000-4-2: 4<sup>th</sup> Ed. (2014-02)

#### 3.2 SERIAL NUMBERS

**Table 3-1: Serial Numbers**

Unit 1
--------

#### 3.3 TEST PROCEDURE

The UUT was subjected to Electrostatic Discharge Testing per IEC 61000-4-2 and in accordance with the referenced documents. Contact discharge was performed at levels of  $\pm 8$  kV at applicable (conductive) test points. Air discharge was performed for non-conductive surfaces of the product at levels of  $\pm 2$  kV,  $\pm 4$  kV,  $\pm 8$  kV and  $\pm 15$  kV. Indirect discharge to the horizontal coupling plane (HCP) and the vertical coupling plane (VCP) were also performed at levels of  $\pm 8$  kV. ESD testing was also performed on applicable patient coupling ports as well as signal input/output ports. If this testing was applicable, it will be documented on the test data sheet.

#### 3.4 SPECIAL CONFIGURATIONS

N/A

#### 3.5 TEST RESULTS

The UUT maintained essential performance and basic safety and therefore complied with the requirements of this test.

Note: In the event that no discharge occurs when ESD testing is performed on a product, the data sheet will state “no [contact or air] discharge points found”.

Electrostatic Discharge Test Data is presented in Appendix A.

#### 4.0 RADIATED RF IMMUNITY TEST

##### 4.1 REFERENCES

IEC 61000-4-3: 4<sup>th</sup> Ed. (2014-02)

##### 4.2 SERIAL NUMBERS

**Table 4-1: Serial Numbers**

Unit 1
--------

##### 4.3 TEST PROCEDURE

Radiated RF immunity testing was performed on the UUT in accordance with the test methods specified in IEC 61000-4-3. The UUT, which was a table-top unit, was placed on a non-conductive table inside the completely anechoic-lined chamber. The frequency range for this testing was 80 MHz – 1.0 GHz and the UUT was placed 2 meters from the radiating antenna, which was 1.5 meters above the floor of the chamber. Testing was performed in both horizontal and vertical antenna polarizations. The frequency was incremented in 1% steps, with a 3 second dwell time for each test frequency. The UUT was rotated so that all four sides were illuminated in the 10 V/m field. The field was amplitude modulated with a 1 kHz sine wave to a depth of 80%.

##### 4.4 SPECIAL CONFIGURATIONS

N/A

##### 4.5 TEST RESULTS

The UUT maintained essential performance and basic safety and therefore complied with the requirements of this test.

Radiated RF Immunity Test Data is presented in Appendix B.

## 5.0 ELECTRICAL FAST TRANSIENT/BURST TEST

### 5.1 REFERENCES

IEC 61000-4-4: 4<sup>th</sup> Ed. (2014-02)

### 5.2 SERIAL NUMBERS

**Table 5-1: Serial Numbers**

Unit 1
--------

### 5.3 TEST PROCEDURE

Electrical fast transient/burst testing was performed on the UUT in accordance with EN 61000-4-4. The UUT's AC power was tested via direct injection at a level of  $\pm 2$  kV. A 100 kHz repetition rate was used for this testing and a minimum of 1 minute was used for each mode of injection.

### 5.4 SPECIAL CONFIGURATIONS

N/A

### 5.5 TEST RESULTS

The UUT maintained essential performance and basic safety and therefore complied with the requirements of this test.

Electrical Fast Transient/burst Test Data is presented in Appendix C.



**6.0 SURGE IMMUNITY TEST****6.1 REFERENCES**

IEC 61000-4-5: 4<sup>th</sup> Ed. (2014-02)

**6.2 SERIAL NUMBERS****Table 6-1: Serial Numbers**

Unit 1
--------

**6.3 TEST PROCEDURE**

Surge immunity testing was performed on the UUT in accordance with the test methods specified in IEC 61000-4-5. The UUT's AC power was tested via direct injection at levels of +0.5 kV, +1.0 kV and +2.0 kV for differential and common modes. Surges were injected at 0 degrees, 90 degrees, 180 degrees and 270 degrees of the input AC waveform. Five pulses were injected for each test configuration and a maximum injection rate of once every 30 seconds was used.

**6.4 SPECIAL CONFIGURATIONS**

N/A

**6.5 TEST RESULTS**

The UUT maintained essential performance and basic safety and therefore complied with the requirements of this test.

Surge Immunity Test Data is presented in Appendix D.

## 7.0 CONDUCTED RF IMMUNITY TEST

### 7.1 REFERENCES

IEC 61000-4-6: 4<sup>th</sup> Ed. (2014-02)

### 7.2 SERIAL NUMBERS

**Table 7-1: Serial Numbers**

Unit 1
--------

### 7.3 TEST PROCEDURE

Conducted RF immunity testing was performed on the UUT in accordance with the test methods specified by IEC 61000-4-6. The UUT was subjected to injected RF signals on its input AC power cable. Injection on the AC leads was performed via a coupling/decoupling network (CDN). The frequency range for this testing was 150 kHz to 80 MHz. The test frequency was stepped in 1% increments with a three (3) second dwell time for each injection frequency. The injection level used for all testing was 10 Vrms and the carrier was amplitude modulated with 1 kHz sine wave to a depth of 80%.

### 7.4 SPECIAL CONFIGURATIONS

N/A

### 7.5 TEST RESULTS

The UUT maintained essential performance and basic safety and therefore complied with the requirements of this test.

Conducted RF Immunity Test Data is presented in Appendix E.

## 8.0 POWER FREQUENCY H-FIELD IMMUNITY TEST

### 8.1 REFERENCES

IEC 61000-4-8: 4<sup>th</sup> Ed. (2014-02)

### 8.2 SERIAL NUMBERS

**Table 8-1: Serial Numbers**

Unit 1
--------

### 8.3 TEST PROCEDURE

Power frequency H-field immunity testing was performed on the UUT in accordance with the test methods specified by IEC 61000-4-8. The UUT was exposed to a 30 A/m field at both 50 and 60 Hz. The immersion method was used for this testing and a 1.5 m x 2.0 m coil was utilized. All three axes (x, y, and z) of the various components were subjected to a field of 30 A/m for a period of 60 seconds per location

### 8.4 SPECIAL CONFIGURATIONS

N/A

### 8.5 TEST RESULTS

The UUT maintained essential performance and basic safety and therefore complied with the requirements of this test.

Power Frequency H-Filed Immunity Test Data is presented in Appendix F.

## 9.0 VOLTAGE DIPS AND INTERRUPTS TEST

### 9.1 REFERENCES

IEC 61000-4-11: 4<sup>th</sup> Ed. (2014-02)

### 9.2 SERIAL NUMBERS

**Table 9-1: Serial Numbers**

Unit 1
--------

### 9.3 TEST PROCEDURE

Voltage dip and interrupt testing was performed on the UUT, in accordance with EN 61000-4-11. The UUT was subjected to the following voltage fluctuations on its AC power input:

- 30% reduction for 0.6 cycles at 0°, 90°, 180°, and 270°
- 60% reduction for 6 cycles at 0°, 90°, 180°, and 270°
- 60% reduction for 60 cycles at 0°, 90°, 180°, and 270°
- 100% reduction for 300 cycles at 0° and 180°

### 9.4 SPECIAL CONFIGURATIONS

N/A

### 9.5 TEST RESULTS

The UUT maintained essential performance and basic safety and therefore complied with the requirements of this test.

Voltage Dips and Interrupts Test Data is presented in Appendix G.

## **APPENDIX A: Electrostatic Discharge Test Data**

**Electrostatic Discharge per IEC / EN 61000-4-2**

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GP1
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 12, 2018
Temperature:	25.4°C	Humidity:	34%
Input Voltage:	120Vac/60Hz	Pressure:	834 mb
Configuration of Unit:	Scanning ballots		
Test Engineer:	Casey Lockhart		

PR085361-4-2.doc

FR0100

Test Location	Voltage Level (kV)	Polarity		Number of Pulses	Pulses Per Second	Comments	Criteria Met	Pass / Fail
		+	-					
Indirect Discharge Points								
VCP	8	x	x	10	1	Front Side	A	Pass
VCP	8	x	x	10	1	Left Side	A	Pass
VCP	8	x	x	10	1	Right Side	A	Pass
VCP	8	x	x	10	1	Back Side	A	Pass
HCP	8	x	x	10	1	Edge of HCP at Front of UUT	A	Pass
Contact Discharge Points - <b>RED</b> Arrows.								
Figure A2	8	x	x	10	1		A	Pass
Figure A3	8	x	x	10	1		A	Pass
Figure A4	8	x	x	10	1		A	Pass
Figure A5	8	x	x	10	1		B	Pass
Air Discharge Points - <b>BLUE</b> Arrows.								
Figure A2	2, 4, 8, 15	x	x	---	---	No discharge points found.	---	---
Figure A3	2, 4, 8, 15	x	x	---	---	No discharge points found.	---	---
Figure A4	2, 4, 8, 15	x	x	10	1		B	Pass
Figure A5	2, 4, 8, 15	x	x	---	---	No discharge points found.	---	---

---

**Electrostatic Discharge per IEC / EN 61000-4-2**

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 12, 2018

PR085361-4-2.doc

FR0100



Figure A1. Electrostatic Discharge Test Setup.

---

**Electrostatic Discharge per IEC / EN 61000-4-2**

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 12, 2018

PR085361-4-2.doc

FR0100




Figure A2. Electrostatic Discharge Test Setup.



---

### Electrostatic Discharge per IEC / EN 61000-4-2

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 12, 2018

PR085361-4-2.doc

FR0100




Figure A3. Electrostatic Discharge Test Setup.

---

**Electrostatic Discharge per IEC / EN 61000-4-2**

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 12, 2018

PR085361-4-2.doc

FR0100




Figure A4. Electrostatic Discharge Test Setup.

---

**Electrostatic Discharge per IEC / EN 61000-4-2**

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 12, 2018

PR085361-4-2.doc

FR0100




Figure A5. Electrostatic Discharge Test Setup.

---

**Electrostatic Discharge per IEC / EN 61000-4-2**


---

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GPI
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 12, 2018

PR085361-4-2.doc FR0100

**Test Equipment List**

ID Number	Manufacturer	Model #	Serial #	Description	Cal Date	Cal Due
1039	Fluke	83-3	69811227	Multimeter/Frequency Meter	10/24/2017	10/24/2018
1249	KeyTek	MZ-15/EC	0609258	ESD Gun with TPC-2A SN:0609259	07/13/2018	07/13/2019
1281	EMC Partner	ESD3000	284	ESD Test System	12/20/2017	12/20/2018
1569	California Instruments by Ametek	5001IX-208-CTS, Series II	1514A02227	5kV Programmable Power Supply	NA	NA
1587	EXTECH Instruments	445715	NA	Hygro-Thermometer	01/25/2018	01/25/2019

## **APPENDIX B: Radiated RF Immunity Test Data**

---



---

**Radiated RF Immunity per IEC / EN 61000-4-3**


---

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	10m2
Model:	ClearCast (Model 2, Version A)	S/N:	Unit 1
Standard Referenced:	EAC 2005 VVSG	Date:	September 6, 2018
Temperature:	24°C	Humidity:	47%
Input Voltage:	120Vac/60Hz	Pressure:	845mb
Configuration of Unit:	Scanning ballots		
Test Engineer:	Kevin Johnson		

PR085361-4-3.doc

FR0100

Frequency (MHz)	Modulation			Step Size (%)	Field (V/m)	Polarity (V or H)	Dwell (sec)	Comments	Criteria Met	Pass / Fail	
	Type	%	Freq								Form
80 - 1000	AM	80	1kHz	Sine	1	10	V	3	<b>Front Side</b>	A	Pass
80 - 1000	AM	80	1kHz	Sine	1	10	H	3		A	Pass
80 - 1000	AM	80	1kHz	Sine	1	10	V	3	<b>Right Side</b>	A	Pass
80 - 1000	AM	80	1kHz	Sine	1	10	H	3		A	Pass
80 - 1000	AM	80	1kHz	Sine	1	10	V	3	<b>Back Side</b>	A	Pass
80 - 1000	AM	80	1kHz	Sine	1	10	H	3		A	Pass
80 - 1000	AM	80	1kHz	Sine	1	10	V	3	<b>Left Side</b>	A	Pass
80 - 1000	AM	80	1kHz	Sine	1	10	H	3		A	Pass



**Radiated RF Immunity per IEC / EN 61000-4-3**

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	10m2
Model:	ClearCast (Model 2, Version A)	S/N:	Unit 1
Standard Referenced:	EAC 2005 VVSG	Date:	September 6, 2018

PR085361-4-3.doc

FR0100




Figure B1. Radiated RF Immunity Test Setup – Front Side.

---

**Radiated RF Immunity per IEC / EN 61000-4-3**

---

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	10m2
Model:	ClearCast (Model 2, Version A)	S/N:	Unit 1
Standard Referenced:	EAC 2005 VVSG	Date:	September 6, 2018

PR085361-4-3.doc

FR0100




Figure B2. Radiated RF Immunity Test Setup – Right Side.



**Radiated RF Immunity per IEC / EN 61000-4-3**

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	10m2
Model:	ClearCast (Model 2, Version A)	S/N:	Unit 1
Standard Referenced:	EAC 2005 VVSG	Date:	September 6, 2018

PR085361-4-3.doc

FR0100




Figure B3. Radiated RF Immunity Test Setup – Back Side.

**Radiated RF Immunity per IEC / EN 61000-4-3**

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	10m2
Model:	ClearCast (Model 2, Version A)	S/N:	Unit 1
Standard Referenced:	EAC 2005 VVSG	Date:	September 6, 2018

PR085361-4-3.doc

FR0100




Figure B4. Radiated RF Immunity Test Setup – Left Side.

**Radiated RF Immunity per IEC / EN 61000-4-3**

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	10m2
Model:	ClearCast (Model 2, Version A)	S/N:	Unit 1
Standard Referenced:	EAC 2005 VVSG	Date:	September 6, 2018
PR085361-4-3.doc		FR0100	

**Test Equipment List**

ID Number	Manufacturer	Model #	Serial #	Description	Cal Date	Cal Due
1005	EMCO	3140	1012	Biconilog Antenna	NA	NA
1024	Amplifier Research	FP4000	18358	Isotropic Field Probe (10 kHz - 1 GHz)	10/04/2017	10/04/2018
1055	Marconi	2024	112113/027	Signal Generator (10 kHz - 2.4 GHz)	05/31/2018	05/31/2019
1181	EMCI	RFS	V2.5.8	Initial Release 02 July 2004	NA	NA
1250	OPHIR	5127F	1034	RF Power Amplifier 20-1000MHz, 200 Watts	NA	NA
1396	CIR Enterprises	10m Chamber #2	002	10m Chamber with 4m turntable	03/29/2018	03/29/2020
1453	Giga-tronics	GT-8888A	8888A0336	10 MHz to 8 GHz, +20 dBm, 25 Vdc Power Meter	03/29/2018	03/29/2019
1492	Fluke	87/5 Multimeter	23350032	True RMS Multimeter	05/08/2018	05/08/2019
1578	Werlatone	C3908-10	107952	1500 Watts, 50 dB Dual Directional Coupler (80MHz)	06/25/2018	06/25/2019
1586	EXTECH Instruments	445715	NA	Hygro-Thermometer	01/25/2018	01/25/2019

## **APPENDIX C: Electrical Fast Transient/Burst Test Data**

---



---

**Electrical Fast Transient/Burst per IEC / EN 61000-4-4**


---

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GP1
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 10, 2018
Temperature:	23.6°C	Humidity:	34%
Input Voltage:	120Vac/60Hz	Pressure:	836 mb
Configuration of Unit:	Scanning ballots		
Test Engineer:	Casey Lockhart		

PR085361-4-4.doc

FR0100

Voltage (kV)	Polarity		Time (sec)	Injection Type	L 1	L 2	L 3	N	P E	Rep Freq.	Comments	Criteria Met	Pass / Fail
	+	-											
2.0	x		60	CDN	x					100 kHz	AC	A	Pass
2.0		x	60	CDN	x					100 kHz		A	Pass
2.0	x		60	CDN		x				100 kHz		A	Pass
2.0		x	60	CDN		x				100 kHz		A	Pass
2.0	x		60	CDN					x	100 kHz		A	Pass
2.0		x	60	CDN					x	100 kHz		A	Pass
2.0	x		60	CDN	x	x			x	100 kHz		A	Pass
2.0		x	60	CDN	x	x			x	100 kHz		A	Pass

**Electrical Fast Transient/Burst per IEC / EN 61000-4-4**

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
 Customer Representative: Stephen Han  
 Model: ClearCast (Model 2, Version A)  
 Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
 Test Area: GP1  
 S/N: CASTD002007  
 Date: September 10, 2018

PR085361-4-4.doc

FR0100




Figure C1. Electrical Fast Transient Test Setup.





---

**Electrical Fast Transient/Burst per IEC / EN 61000-4-4**


---

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GPI
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	FCC Part 15, EAC 2005 VVSG	Date:	September 10, 2018

PR085361-4-4.doc FR0100

**Test Equipment List**

ID Number	Manufacturer	Model #	Serial #	Description	Cal Date	Cal Due
1039	Fluke	83-3	69811227	Multimeter/Frequency Meter	10/24/2017	10/24/2018
1184	KeyTek	CEWare	4.0	KeyTek EMCPro Control Software for EFT, Surge, H-F	NA	NA
1284	ThermoFischer Scientific	EMC Pro Plus - USA	0705276	EFT, Surge, H-field & PQF Immunity Test Generator	07/05/2018	07/05/2019
1371	Tektronix	TDS2002B	C103483	Oscilloscope, 60 MHz, 2-channel	01/26/2018	01/26/2019
1587	EXTECH Instruments	445715	NA	Hygro-Thermometer	01/25/2018	01/25/2019



## **APPENDIX D: Surge Immunity Test Data**

**Surge Immunity per IEC / EN 61000-4-5**

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GP1
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 11, 2018
Temperature:	26.2°C	Humidity:	30%
Input Voltage:	120Vac/60Hz	Pressure:	835 mb
Configuration of Unit:	Scanning ballots		
Test Engineer:	Casey Lockhart		

PR085361-4-5.doc

FR0100

Voltage (kV)	Polarity		L1	L2	L3	N	P	E	Phase (deg)	Number of Pulses	Delay (sec)	Comments	Criteria Met	Pass / Fail
	+	-												
0.5	x		x			x			0	5	30	Differential Mode	A	Pass
0.5		x	x			x			0	5	30		A	Pass
0.5	x		x			x			90	5	30		A	Pass
0.5		x	x			x			90	5	30		A	Pass
0.5	x		x			x			180	5	30		A	Pass
0.5		x	x			x			180	5	30		A	Pass
0.5	x		x			x			270	5	30		A	Pass
0.5		x	x			x			270	5	30		A	Pass
0.5	x		x				x		0	5	30	Common Mode Line	A	Pass
0.5		x	x				x		0	5	30		A	Pass
0.5	x		x				x		90	5	30		A	Pass
0.5		x	x				x		90	5	30		A	Pass
0.5	x		x				x		180	5	30		A	Pass
0.5		x	x				x		180	5	30		A	Pass
0.5	x		x				x		270	5	30		A	Pass
0.5		x	x				x		270	5	30		A	Pass
0.5	x					x	x		0	5	30	Common Mode Neutral	A	Pass
0.5		x				x	x		0	5	30		A	Pass
0.5	x					x	x		90	5	30		A	Pass
0.5		x				x	x		90	5	30		A	Pass
0.5	x					x	x		180	5	30		A	Pass
0.5		x				x	x		180	5	30		A	Pass
0.5	x					x	x		270	5	30		A	Pass
0.5		x				x	x		270	5	30		A	Pass

**Surge Immunity per IEC / EN 61000-4-5**

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GP1
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 11, 2018
Temperature:	26.2°C	Humidity:	30%
Input Voltage:	120Vac/60Hz	Pressure:	835 mb
Configuration of Unit:	Scanning ballots		
Test Engineer:	Casey Lockhart		

PR085361-4-5.doc

FR0100

Voltage (kV)	Polarity		L 1	L 2	L 3	N	P E	Phase (deg)	Number of Pulses	Delay (sec)	Comments	Criteria Met	Pass / Fail
	+	-											
1.0	x		x			x		0	5	45	Differential Mode	A	Pass
1.0		x	x			x		0	5	45		A	Pass
1.0	x		x			x		90	5	45		A	Pass
1.0		x	x			x		90	5	45		A	Pass
1.0	x		x			x		180	5	45		A	Pass
1.0		x	x			x		180	5	45		A	Pass
1.0	x		x			x		270	5	45		A	Pass
1.0		x	x			x		270	5	45		A	Pass
1.0	x		x			x		0	5	45	Common Mode Line	A	Pass
1.0		x	x			x		0	5	45		A	Pass
1.0	x		x			x		90	5	45		A	Pass
1.0		x	x			x		90	5	45		A	Pass
1.0	x		x			x		180	5	45		A	Pass
1.0		x	x			x		180	5	45		A	Pass
1.0	x		x			x		270	5	45		A	Pass
1.0		x	x			x		270	5	45		A	Pass
1.0	x					x	x	0	5	45	Common Mode Neutral	A	Pass
1.0		x				x	x	0	5	45		A	Pass
1.0	x					x	x	90	5	45		A	Pass
1.0		x				x	x	90	5	45		A	Pass
1.0	x					x	x	180	5	45		A	Pass
1.0		x				x	x	180	5	45		A	Pass
1.0	x					x	x	270	5	45		A	Pass
1.0		x				x	x	270	5	45		A	Pass
2.0	x		x			x		0	5	60	Differential Mode	A	Pass

**Surge Immunity per IEC / EN 61000-4-5**

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GP1
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 11, 2018
Temperature:	26.2°C	Humidity:	30%
Input Voltage:	120Vac/60Hz	Pressure:	835 mb
Configuration of Unit:	Scanning ballots		
Test Engineer:	Casey Lockhart		

PR085361-4-5.doc

FR0100

Voltage (kV)	Polarity		L 1	L 2	L 3	N	P E	Phase (deg)	Number of Pulses	Delay (sec)	Comments	Criteria Met	Pass / Fail
	+	-											
2.0		x	x			x		0	5	60		A	Pass
2.0	x		x			x		90	5	60		A	Pass
2.0		x	x			x		90	5	60		A	Pass
2.0	x		x			x		180	5	60		A	Pass
2.0		x	x			x		180	5	60		A	Pass
2.0	x		x			x		270	5	60		A	Pass
2.0		x	x			x		270	5	60		A	Pass
2.0	x		x				x	0	5	60	Common Mode Line	A	Pass
2.0		x	x				x	0	5	60		A	Pass
2.0	x		x				x	90	5	60		A	Pass
2.0		x	x				x	90	5	60		A	Pass
2.0	x		x				x	180	5	60		A	Pass
2.0		x	x				x	180	5	60		A	Pass
2.0	x		x				x	270	5	60		A	Pass
2.0		x	x				x	270	5	60		A	Pass
2.0	x					x	x	0	5	60	Common Mode Neutral	A	Pass
2.0		x				x	x	0	5	60		A	Pass
2.0	x					x	x	90	5	60		A	Pass
2.0		x				x	x	90	5	60		A	Pass
2.0	x					x	x	180	5	60		A	Pass
2.0		x				x	x	180	5	60		A	Pass
2.0	x					x	x	270	5	60		A	Pass
2.0		x				x	x	270	5	60		A	Pass

**Surge Immunity per IEC / EN 61000-4-5**

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GP1
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 11, 2018

PR085361-4-5.doc

FR0100




Figure D1. Surge Immunity Test Setup.

---

**Surge Immunity per IEC / EN 61000-4-5**

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 11, 2018

PR085361-4-5.doc

FR0100




Figure D2. Surge Immunity Test Setup – AC Mains.

---

**Surge Immunity per IEC / EN 61000-4-5**

---

Manufacturer:	<u>Clear Ballot Group (manufacturer) Pro V&amp;V (client)</u>	Project Number:	<u>PR085361</u>
Customer Representative:	<u>Stephen Han</u>	Test Area:	<u>GPI</u>
Model:	<u>ClearCast (Model 2, Version A)</u>	S/N:	<u>CASTD002007</u>
Standard Referenced:	<u>EAC 2005 VVSG</u>	Date:	<u>September 11, 2018</u>

PR085361-4-5.doc FR0100

**Test Equipment List**

ID Number	Manufacturer	Model #	Serial #	Description	Cal Date	Cal Due
1039	Fluke	83-3	69811227	Multimeter/Frequency Meter	10/24/2017	10/24/2018
1184	KeyTek	CEWare	4.0	KeyTek EMCPro Control Software for EFT, Surge, H-F	NA	NA
1284	ThermoFischer Scientific	EMC Pro Plus - USA	0705276	EFT, Surge, H-field & PQF Immunity Test Generator	07/05/2018	07/05/2019
1371	Tektronix	TDS2002B	C103483	Oscilloscope, 60 MHz, 2-channel	01/26/2018	01/26/2019
1587	EXTECH Instruments	445715	NA	Hygro-Thermometer	01/25/2018	01/25/2019
1596	California Instruments & AMETEK	iXGui	V3.0.0	AC Source Control and Scripting Software	NA	NA

## **APPENDIX E: Conducted RF Immunity Test Data**



---



---

**Conducted RF Immunity per IEC / EN 61000-4-6**


---

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GP1
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 10, 2018
Temperature:	22.8°C	Humidity:	32%
Input Voltage:	120Vac/60Hz	Pressure:	836 mb
Configuration of Unit:	Scanning ballots		
Test Engineer:	Casey Lockhart		

PR085361-4-6.doc

FR0100

Frequency (MHz)	Modulation			Level (Vrms)	Dwell (sec)	Comments	Criteria Met	Pass / Fail
	Type	%	Freq					
0.150 – 80.0	AM	80	1 kHz	10	3	AC using M3 CDN	A	Pass

---

**Conducted RF Immunity per IEC / EN 61000-4-6**

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 10, 2018

PR085361-4-6.doc

FR0100




Figure E1. Conducted RF Immunity Test Setup.

---

**Conducted RF Immunity per IEC / EN 61000-4-6**

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 10, 2018

PR085361-4-6.doc

FR0100




Figure E2. Conducted RF Immunity Test Setup – AC Mains.

**Conducted RF Immunity per IEC / EN 61000-4-6**

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GPI
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 10, 2018
PR085361-4-6.doc			FR0100

**Test Equipment List**

ID Number	Manufacturer	Model #	Serial #	Description	Cal Date	Cal Due
1039	Fluke	83-3	69811227	Multimeter/Frequency Meter	10/24/2017	10/24/2018
1261	Hewlett Packard	8648C	3619U00779	Signal Generator, 100kHz to 3.2GHz	10/24/2017	10/24/2018
1379	IFI	M100	O1200-0111	100W Power Amplifier, 0.01 MHz to 220 MHz	NA	NA
1480	EMCI	EMCI-CDN-M3-16	EMCI015	M3 CDN, 16A, 250 VAC	11/13/2017	11/13/2018
1496	Rigol Technologies, Inc.	DSA815	DSA8B150500096	9 kHz to 1.5 GHz Spectrum Analyzer	03/26/2018	03/26/2019
1528	Aeroflex/Wein schel	40-6-34	SB031	Hi power atten 6 dB	10/12/2017	10/12/2018
1532	Werlatone	C9475-13	102545	100 Watt Dual Directional Coupler, 10 kHz to 250 M	10/12/2017	10/12/2018
1569	California Instruments by Ametek	5001IX-208-CTS, Series II	1514A02227	5kV Programmable Power Supply	NA	NA
1587	EXTECH Instruments	445715	NA	Hygro-Thermometer	01/25/2018	01/25/2019
1594	EMCI	CI	V2.5.0	Conducted Immunity Software	NA	NA

## **APPENDIX F: Power Frequency H-Field Test Data**

---



---

**Power Frequency H-field Immunity per IEC / EN 61000-4-8**


---

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GPI
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 11, 2018
Temperature:	24.0°C	Humidity:	42%
Input Voltage:	120Vac/60Hz	Pressure:	835 mb
Configuration of Unit:	Scanning ballots		
Test Engineer:	Casey Lockhart		

PR085361-4-8.doc

FR0100

Frequency (Hz)		Field Strength (A/m)	EUT Axis Location	Dwell Time (sec)	Comments	Criteria Met	Pass / Fail
50	60						
x		30	X	60		A	Pass
	x	30	X	60		A	Pass
x		30	Y	60		A	Pass
	x	30	Y	60		A	Pass
x		30	Z	60		A	Pass
	x	30	Z	60		A	Pass
x		30	Z	60	Extra axis to cover monitor.	A	Pass
	x	30	Z	60	Extra axis to cover monitor.	A	Pass

---

### Power Frequency H-field Immunity per IEC / EN 61000-4-8

---

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GP1
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 11, 2018

PR085361-4-8.doc

FR0100



Figure F1. Power Frequency H-field Immunity Test Setup X axis.



---

**Power Frequency H-field Immunity per IEC / EN 61000-4-8**

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 11, 2018

PR085361-4-8.doc

FR0100



Figure F2. Power Frequency H-field Immunity Test Setup Y axis.



---

**Power Frequency H-field Immunity per IEC / EN 61000-4-8**

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 11, 2018

PR085361-4-8.doc

FR0100



Figure F3. Power Frequency H-field Immunity Test Setup Z axis.

---

**Power Frequency H-field Immunity per IEC / EN 61000-4-8**

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 11, 2018

PR085361-4-8.doc

FR0100



Figure F4. Power Frequency H-field Immunity Test Setup extra Z axis.

---

**Power Frequency H-field Immunity per IEC / EN 61000-4-8**


---

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GPI
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 11, 2018

PR085361-4-8.doc FR0100

**Test Equipment List**

ID Number	Manufacturer	Model #	Serial #	Description	Cal Date	Cal Due
1039	Fluke	83-3	69811227	Multimeter/Frequency Meter	10/24/2017	10/24/2018
1371	Tektronix	TDS2002B	C103483	Oscilloscope, 60 MHz, 2-channel	01/26/2018	01/26/2019
1587	EXTECH Instruments	445715	NA	Hygro-Thermometer	01/25/2018	01/25/2019
1505	EMCI	EMCI-4-8-2m-1.5m	0002	HField Loop, 2m x 1.5m	08/28/2017	09/28/2018
1549	California Instruments/A metek	1251P	1423A05348	AC power supply	NA	NA
1485	Pearson Electronics	110A	90561	Current Monitor, 1 Hz to 20 MHz	11/28/2017	11/28/2018

## **APPENDIX G: Voltage Dips and Interrupts Test Data**

### Voltage Dips and Interrupts per IEC / EN 61000-4-11

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GP1
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 10, 2018
Temperature:	23.6°C	Humidity:	32%
Input Voltage:	120Vac/60Hz	Pressure:	836 mb
Configuration of Unit:	Scanning ballots		
Test Engineer:	Casey Lockhart		

PR085361-4-11.doc

FR0100

% Nominal	No. of Cycles	Phase Angle (deg)				Time between dropouts (sec)	Number of tests	Comments	Criteria Met	Pass / Fail
		0	90	180	270					
70%	0.6	x				10	3		A	Pass
70%	0.6		x			10	3		A	Pass
70%	0.6			x		10	3		A	Pass
70%	0.6				x	10	3		A	Pass
40%	6	x				10	3		A	Pass
40%	6		x			10	3		A	Pass
40%	6			x		10	3		A	Pass
40%	6				x	10	3		A	Pass
40%	60	x				10	3		A	Pass
40%	60		x			10	3		A	Pass
40%	60			x		10	3		A	Pass
40%	60				x	10	3		A	Pass
0%	300	x				10	3		A	Pass
0%	300			x		10	3		A	Pass
Line Voltage Variation tests										
129Vac Line Voltage Variations (+7.5% of nominal 120V) 3hrs.									A	Pass
105Vac Line Voltage Variations (-12.5% of nominal 120V) 3 Hrs.									A	Pass
Surges of -15% line variations of nominal voltage (102V) 1 Hrs									A	Pass
Surges of -15% line variations of nominal voltage (138V) 1 Hrs									A	Pass

---

**Voltage Dips and Interrupts per IEC / EN 61000-4-11**

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 10, 2018

PR085361-4-11.doc

FR0100



Figure G1. Voltage Dips and Interrupts Test Setup.



---

### Voltage Dips and Interrupts per IEC / EN 61000-4-11

---

Manufacturer: Clear Ballot Group (manufacturer) Pro V&V (client)  
Customer Representative: Stephen Han  
Model: ClearCast (Model 2, Version A)  
Standard Referenced: EAC 2005 VVSG

Project Number: PR085361  
Test Area: GP1  
S/N: CASTD002007  
Date: September 10, 2018

PR085361-4-11.doc

FR0100



Figure G2. Voltage Dips and Interrupts Test Setup.

---

**Voltage Dips and Interrupts per IEC / EN 61000-4-11**


---

Manufacturer:	Clear Ballot Group (manufacturer) Pro V&V (client)	Project Number:	PR085361
Customer Representative:	Stephen Han	Test Area:	GPI
Model:	ClearCast (Model 2, Version A)	S/N:	CASTD002007
Standard Referenced:	EAC 2005 VVSG	Date:	September 10, 2018

PR085361-4-11.doc FR0100

**Test Equipment List**

ID Number	Manufacturer	Model #	Serial #	Description	Cal Date	Cal Due
1039	Fluke	83-3	69811227	Multimeter/Frequency Meter	10/24/2017	10/24/2018
1184	KeyTek	CEWare	4.0	KeyTek EMCPro Control Software for EFT, Surge, H-F	NA	NA
1284	ThermoFischer Scientific	EMC Pro Plus - USA	0705276	EFT, Surge, H-field & PQF Immunity Test Generator	07/05/2018	07/05/2019
1371	Tektronix	TDS2002B	C103483	Oscilloscope, 60 MHz, 2-channel	01/26/2018	01/26/2019
1569	California Instruments by Ametek	5001IX-208-CTS, Series II	1514A02227	5kV Programmable Power Supply	NA	NA
1587	EXTECH Instruments	445715	NA	Hygro-Thermometer	01/25/2018	01/25/2019



## **APPENDIX H: Product Data Sheet**

## 1.0 Client Information

Client Information	
Manufacturer Name	Clear Ballot Group (manufacturer) Pro V&V (client)
Address	700 Boulevard South Suite 102
City	Huntsville
State	AL
Zip Code	35802
Client Representative	Stephen Han
Title	Sr. Project Engineer
Phone	256-713-1111
Fax	256-713-1112
Email	stephen.han@provandv.com

## 2.0 Product Information - General

Product Information						
Product Name (as it should appear on test report)	ClearCast					
Model Number (of UUT to be tested)	ClearCast					
Functional description of product (what is it, what does it do, etc.)	Precinct Tabulator					
List all modes of operation	Normal					
Can modes be operated simultaneously? If so, explain.	No					
What mode(s) will be used for testing?	Normal					
Product type (IT, Medical, Scientific, Industrial, etc.)	IT					
Is the product an intentional radiator	no					
Product Dimensions						
Product Weight						
Will fork lift be required	No					
Applicable Standards, if known	EAC 2005 VVSG Volumes I and II					
Describe all environment(s) where product will be used (residential, commercial, industrial, etc.)	Used for voting during elections					
Does product consist of multiple components? (If yes, please describe each system component)	No					
Cycle time > 3 seconds? (If yes, how long?)	Yes. 5 sec					
Highest internally generated frequency						
Product Set-up Time	15 minutes					
Boot up time in the event of an unintentional power down	0 minutes - internal backup battery					
Identify <b>ALL</b> I/O connections on the unit(s) under test, as well as <b>MAXIMUM</b> associated cable lengths below						
Model No.	Description	I/O Type		Length (m)	Patient Connect? (See Note)	QTY
		UUT-UUT	UUT-SE			
	power					
Note: "Patient Connect" column applies only to medical devices.						

### 3.0 Power

Power Requirements	
Does/can product connect to AC mains? (If so, can the UUT function when connected to AC?)	Yes.
Input Voltage Rating as it appears on unit, power supply, or power brick	115 VAC ; 230 VAC
Input Current (specify @ 230 Vac/50 Hz)	Normal
Single or Multi-Phase (If multi-phase, specify delta or wye)	single
Is input power connector two-prong (Hot & Neutral) or 3-prong (H, N, Ground)	3 prong
Does UUT have more than 1 power cord? (If yes, explain.)	No


### 4.0 Unit Under Test (UUT) – Detailed Information

UUT Hardware			
<b>Condition</b>	New		
<b>Configuration During Test</b>	Scanning ballots		
<b>Input Power</b>	Normal AC power		
UUT Components			
Name	Model No.	Serial No.	Description
ClearCast	Model 2, Version A	Unit 1	Precinct Tabulator
I/O Cabling			
See Section 2.0 for details			
UUT Software/Firmware			
Name	Version/Revision	Functionality	
ClearCast	N/A	Voting systems software	
UUT Operating Conditions			
List all frequencies generated/used by the product.	n/a		
How will product be exercised during test?	Scanning Ballots		
How will product be monitored during test?	Visually		
What are the product's critical parameters?	Unit keeps scanning		
Specify tolerance of all critical parameters.	Unit keeps scanning		

### 5.0 Support Equipment (SE) – Detailed Information

Support Equipment (SE)				
Name	Model No.	Serial No.	Description	
n/a				
SE I/O Cabling				
Model No.	Description	Shielded?	Length	Quantity
n/a				
SE Software/Firmware				
Name	Version/Revision	Functionality		
n/a				

### 6.0 Block Diagram



**Important note:** The product data sheet is a critical piece of documentation which is used as the basis for any test reports that NTS will generate; it must be completed *prior* to testing. It should be reviewed carefully by the client. If incorrect information is provided resulting in revisions to test reports, the client will be subject to report revision fees.

## **APPENDIX I: Test Log**

---



---

**EMI\ENV Test Log**


---

Manufacturer: <u>Pro V&amp;V</u>	Project Number: <u>PR085361</u>
Model: <u>Clear Ballot Group (manufacturer) Pro V&amp;V (client)</u>	S/N: <u>Unit 1</u>
Customer Representative: <u>Michael Walker</u>	
Standard Referenced: <u>FCC Part 15, EAC 2005 VVSG</u>	

FR0105

**10m Emissions**

Test	Test Code	Date	Event	O T	Time (hrs)	Result	Initials
RE	6001	September 6, 2018 0800-0900	Setup for RE		1.0	Complete	KJ
RE	1342	0900-1000	Test#1: 30MHz – 1GHz, 8 rads, 4 heights, 3 second dwell, ref level = 80dB, 10 meter test distance. 120Vac/60Hz FCC Class B Unit failing multiple frequencies		1.0	Fail	KJ
		1000-1100	Test#2: 30MHz – 1GHz, 8 rads, 4 heights, 3 second dwell, ref level = 80dB, 10 meter test distance. 120Vac/60Hz FCC Class B RE Troubleshooting <b>Ferrite on the HDMI cable and internal power cable.</b>		1.0	Fail	KJ





**EMI/ENV Test Log**

Manufacturer:	Pro V&V	Project Number:	PR085361
Model:	Clear Ballot Group (manufacturer) Pro V&V (client)	S/N:	Unit 1
Customer Representative:	Michael Walker		
Standard Referenced:	FCC Part 15, EAC 2005 VVSG		

FR0105

**10m Emissions**

Test	Test Code	Date	Event	O T	Time (hrs)	Result	Initials
							
		1100-1200	Test#3: 30MHz – 1GHz, 8 rads, 4 heights, 3 second dwell, ref level = 80dB, 10 meter test distance. 120Vac/60Hz FCC Class B RE Troubleshooting Ferrite on the HDMI cable and internal power cable. <b>Ferrite on 3 USB cables</b>		1.0	Fail	KJ
							

---

**EMI/ENV Test Log**


---

Manufacturer:	Pro V&V	Project Number:	PR085361
Model:	Clear Ballot Group (manufacturer) Pro V&V (client)	S/N:	Unit 1
Customer Representative:	Michael Walker		
Standard Referenced:	FCC Part 15, EAC 2005 VVSG		

FR0105

**10m Emissions**

Test	Test Code	Date	Event	O T	Time (hrs)	Result	Initials
RE	1351	1230-1330	Test#4: 1GHz – 18GHz, 16 rads, 2 heights, 3 second dwell, ref level = 107dB, 3 meter test distance. 120Vac/60Hz FCC Class B Client does not want to measure any signals.		1.0	Complete	KJ
CE	2341	1330-1430	Test#5: 150KHz – 30MHz 120Vac/60Hz FCC Class B		1.0	Pass	KJ
RI	4398	1430-1630	Radiated RF Immunity (4.1.2.10) 10V/m, 80 - 1000 MHz, 1% Step, 80% AM, 1kHz sine, 3s dwell 120 VAC / 60 Hz EAC 2005 VVSG Did the back side V-pole		2.0	Complete	KJ
RI		September 7, 2018 0800-1200	Finishing Radiated RF Immunity Unit stopped at 239MHz, V-pole, left side. Did not repeat.		4.0	Pass	KJ
RE		1230-1300	Test#6: 30MHz – 1GHz, 8 rads, 4 heights, 3 second dwell, ref level = 80dB, 10 meter test distance. 120Vac/60Hz Cable re-positioning, cable management and ferrites Unit failed at 668MHz by .5dB		0.5	Fail	KJ
RE		1330-1430	Test#7: 30MHz – 1GHz, 8 rads, 4 heights, 3 second dwell, ref level = 80dB, 10 meter test distance. 120Vac/60Hz HDMI cable shielded with foil with ferrites Output power cable shielded		1.0	Pass	KJ





**EMI/ENV Test Log**

Manufacturer:	Pro V&V	Project Number:	PR085361
Model:	Clear Ballot Group (manufacturer) Pro V&V (client)	S/N:	Unit 1
Customer Representative:	Michael Walker		
Standard Referenced:	FCC Part 15, EAC 2005 VVSG		

FR0105

**10m Emissions**

Test	Test Code	Date	Event	O T	Time (hrs)	Result	Initials
							
							
			NOTE: Client says that they do not need to finish 1GHz to 18GHz Radiated emissions.				

Regular hours:	13.5
Overtime/Prem hours:	
Total hours:	13.5

**Ground Planes / CALC**

Test	Test Code	Date	Event	O T	Time (hrs)	Result	Initials
4-6	4622	September 10, 2018 0800 - 0900	Conducted RF Immunity (4.1.2.11) 10Vrms, 0.15 - 80 MHz, 1% Step, 80% AM, 1kHz sine, 3s dwell <b>120 VAC / 60 Hz</b>		1.0	Pass	CL
4-4	4411	0900 - 0930	Electrical Fast Transient / Burst (4.1.2.6) Mains: +/- 2kV, I/O: +/- 1kV 120 VAC / 60 Hz @ 100kHz rep rate. Also ran at 5kHz rep rate.		0.5	Pass	CL
4-11	4196	0930 - 1000	Voltage Dips and Interruptions (Inc./Red. of Nom. Voltage) (4.1.2.5) Electric power increases of 7.5% and reductions of 12.5% of nominal specified power. (See Protocol) 120 VAC / 60 Hz		0.5	Pass	CL
---	---	1000 - 1300	129Vac Line Voltage Variations (+7.5% of nominal 120V) 3hrs.		3.0	Pass	CL
---	---	1300 - 1600	105Vac Line Voltage Variations (-12.5% of nominal 120V) 3 Hrs.		3.0	Pass	CL
---	---	September 11, 2018 0800 - -9000	Surges of -15% line variations of nominal voltage (102V) 1 Hrs		1.0	Pass	CL
---	---	0900 - 1000	Surges of + 15% of line variations of nominal (138Vac) 1 Hrs.		1.0	Pass	CL
4-5	4596	1000 - 1530	Surge Immunity (4.1.2.7) Mains: +/- 2kV CM, +/- 2kV DM, (0, 90, 180, 270) 120 VAC / 60 Hz <b>Note: Post-test verification found touch screen not responding. Will replace screen and re-test tomorrow.</b>		5.5	---	CL
4-8	4831	1530 - 1630	Power Frequency H-Field Immunity (4.1.2.12) 30A/m, 50 / 60 Hz, 3 axes 120 VAC / 60 Hz		1.0	Pass	CL
4-5	---	September 12, 2018 0800 - 1300	Re-test Surge Immunity (4.1.2.7) Mains: +/- 2kV CM, +/- 2kV DM, (0, 90, 180, 270) 120 VAC / 60 Hz		5.0	Pass	CL
4-2	4254	1300 - 1500	Electrostatic Discharge Note: Pre-test performed, cables are .931 and .947 (4.1.2.8) +/- 8kV Contact, +/-2, 4, 8, 15kV Air 120 VAC / 60 Hz		2.0	Pass	CL

Regular hours:	23.5
Overtime/Prem hours:	
Total hours:	23.5



Project #:PR085361      Work Order #: 2018080601  
 B80857

PO#: \_\_\_\_\_  
 Amount: \_\_\_\_\_

Company: Pro V&V  
 700 Boulevard South  
 Suite 102  
 Huntsville, AL 35802  
 Phone: 256-713-11111  
 Fax: \_\_\_\_\_

Contact: Michael Walker  
 Email: michael.walker@provandv.com

Model#: \_\_\_\_\_  
 Serial #: \_\_\_\_\_

Test Notes: Voting Machine Testing  
 Three (5) units for test  
 PQF: Increase/decrease = 3 hrs each +/-, 6 hrs total per unit  
 PQF: Surge = 4 hrs each  
 Data sheet folder for each unit  
 Formal test reports

Quoted Work						
Date	Test Code	Description	Standard	Result		Billed
September 6, 2018	1342	Radiated Emissions, 30 MHz - 1 GHz (4.1.2.9) 30 MHz - 1 GHz 120 VAC / 60 Hz	FCC Part 15, Class B	Pass		
September 6, 2018	1351	Radiated Emissions, 1 GHz - 18 GHz (4.1.2.9) 1 GHz - 18 GHz 120 VAC / 60 Hz	FCC Part 15, Class B	Fail		
September 6, 2018	2341	Conducted Emissions, 150 kHz - 30 MHz (4.1.2.9) -- 120 VAC / 60 Hz	FCC Part 15, Class B	Pass		
September 12, 2018	4254	Electrostatic Discharge (4.1.2.8) +/- 8kV Contact, +/-2, 4, 8, 15kV Air 120 VAC / 60 Hz	EN61000-4-2	Pass		
September 6, 2018	4398	Radiated RF Immunity (4.1.2.10) 10V/m, 80 - 1000 MHz, 1% Step, 80% AM, 1kHz sine, 3s dwell 120 VAC / 60 Hz	--	Pass		
September 10, 2018	4411	Electrical Fast Transient / Burst (4.1.2.6) Mains: +/- 2kV, I/O: +/- 1kV 120 VAC / 60 Hz	EN61000-4-4	Pass		
September 11, 2018	4596	Surge Immunity (4.1.2.7) Mains: +/- 2kV CM, +/- 2kV DM, (0, 90, 180, 270) 120 VAC / 60 Hz	EN61000-4-5	Pass		

September 10, 2018	4622	Conducted RF Immunity (4.1.2.11) 10Vrms, 0.15 - 80 MHz, 1% Step, 80% AM, 1kHz sine, 3s dwell 120 VAC / 60 Hz	EN61000-4-6	Pass		
September 11, 2018	4831	Power Frequency H-Field Immunity (4.1.2.12) 30A/m, 50 / 60 Hz, 3 axes 120 VAC / 60 Hz	EN61000-4-8	Pass		
September 10, 2018	4196	Voltage Dips and Interruptions (Inc./Red. of Nom. Voltage) (4.1.2.5) Electric power increases of 7.5% and reductions of 12.5% of nominal specified power. (See Protocol) 120 VAC / 60 Hz	EN61000-4-11	Pass		
September 11, 2018	4194	Voltage Dips and Interruptions (Surge of +/- 15%) (4.1.2.5) Surge of +/- 15% line variation of nominal line voltage 120 VAC / 60 Hz	EN61000-4-11	Pass		
September 10, 2018	4193	Voltage Dips and Interruptions (4.1.2.5) 70% nom, 0.6 cycles / 40% nom, 6 cycles & 1 sec. / 0% nom, 300 cycles 120 VAC / 60 Hz	EN61000-4-11	Pass		
September 6, 2018	6001	Initial Product Set-up & Configuration Engineering / Trouble-Shoot ---	--			
	9010	Immunity Test Report - Soft Copy -- --	--			
	9040	Emissions Test Report - Soft Copy -- --	--			

### Unquoted Work

Date	Test Code	Description	Cost	Billed

### Modifications Required For Compliance

Test	Description of Modification	Client Initials
RE	(1) 742 717 22 Wurth ferrite (1) 742 711 42 Wurth ferrite (1) 742 711 32 Wurth ferrite (2) 742 758 13 Wurth ferrites (2) 742 758 12 Wurth ferrites Shielded HDMI and output power cable See photo in test log. <b>Red</b> arrows for ferrites and <b>blue</b> arrows for shielded cable	



<b>Modifications Required For Compliance</b>		
<b>Test</b>	<b>Description of Modification</b>	<b>Client Initials</b>

Shipping Instructions:		<b>Client Initials</b>

Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

Test Engineer: \_\_\_\_\_ Date: \_\_\_\_\_

I, the client, verify that all the information provided concerning the unit which was tested, support equipment, etc., was accurate. This includes, but is not limited to, information provided via EMC Test Plan and/or EMC Test Protocol, information provided to complete NTS's Product Data Sheet, etc.

Furthermore, I understand that my company may be assessed report revision fees for any report revisions resulting from inaccurate or incomplete information provided.

Client: \_\_\_\_\_ Date: \_\_\_\_\_

Invoice Complete Invoice #: \_\_\_\_\_

## **APPENDIX J: Laboratory Accreditations**



SCOPE OF ACCREDITATION TO ISO/IEC 17025:2005

NATIONAL TECHNICAL SYSTEMS (NTS) - LONGMONT  
 1736 Vista View Drive  
 Longmont, CO 80504-5242  
 Mr. Eric Loucks Phone: 303 776 7249

ELECTRICAL

Valid To: September 30, 2018

Certificate Number: 0214.43

In recognition of the successful completion of the A2LA evaluation process, accreditation is granted to this laboratory to perform the following Electromagnetic Compatibility/Interference (EMC/EMI), Lightning, Transient, Surge, and Product Safety tests:

<u>Test Technology:</u>	<u>Test Method(s)<sup>1,2</sup>:</u>
<i>Emissions</i>	
Radiated and Conducted	CFR 47 FCC, Parts 15B (using ANSI C63.4: 2014), 15C (using ANSI C63.10:2013), and 18 (using MP-5:1986); CISPR 32, Ed. 1 (2012-01); EN 55032:2012/AC:2013; AS/NZS CISPR 22 (2002); AS/NZS 3548 (1997); AS/NZS CISPR 14-1 (2003); IEC/CISPR 14-1, Ed. 4 (2003); IEC 61000-3-12, Ed. 2.0 (2011); EN 61000-3-12 (2011); IEC 61000-6-1, Ed. 2 (2005-03); IEC 61000-6-2, Ed. 2.0 (2005-01); IEC 61000-6-3 (1996); EN 61000-6-3 (2001) + A1 (2004); EN 61000-6-4 (2007); KN 32:2015 (Annex 11); KN 22; KN 11
Harmonics	IEC 61000-3-2, Ed. 2.2 (2004-11); IEC 61000-3-2, Ed. 3.0 (2005) + A1 (2008) + A2 (2009); IEC 61000-3-2, Ed. 4.0 (2014-05)
Flicker	IEC 61000-3-3, Ed. 1.1 (2002-03); EN 61000-3-3 + A1 (2001); IEC 61000-3-3, Ed. 1.1 (2003) + A2 (2005); IEC 61000-3-3, Ed. 3.0 (2013-05)
<i>Immunity</i>	
Electrostatic Discharge (ESD)	IEC 61000-4-2 (2001); EN 61000-4-2 (2001) + A2 (2001); EN 61000-4-2 + A1 (1998) + A2 (2001); IEC 61000-4-2, Ed. 2.0 (2008-12); EN 61000-4-2 (2009-05); KN 61000-4-2; KN 61000-4-2 (2008-5); KN 61000-4-2 (Annex 1-1)
Radiated	IEC/EN 61000-4-3, Ed. 2.1 (2002) + A1 (2002); EN 61000-4-3; IEC 61000-4-3 (1995) + A1 (1998) + A2 (2000); EN 61000-4-3 (2002) + A1 (2002); IEC 61000-4-3, Ed. 3.0 (2006-02) + A1 (2007) + A2 (2010); EN 61000-4-3 (2006) + A1 (2008) + A2 (2010); KN 61000-4-3; KN 61000-4-3 (2008-5); KN 61000-4-3 (Annex 1-2)

(A2LA Cert. No. 0214.43) Revised 08/30/2018

 Page 1 of 4

<u>Test Technology:</u>	<u>Test Method(s)<sup>1,2</sup>:</u>
<i>Immunity (cont'd)</i>	
Electrical Fast Transient/Burst	IEC 61000-4-4, Ed. 2.0 (2004-07); EN 61000-4-4 (2004); EN 61000-4-4:2012; IEC 61000-4-4 (2012-04); KN 61000-4-4; KN 61000-4-4 (2008-5); KN 61000-4-4 (Annex 1-3)
Surge	IEC 61000-4-5, Ed. 2.0 (2005-11); EN 61000-4-5; IEC 61000-4-5, Ed. 3.0 (May 2014); BS EN 61000-4-5 (2006); EN 61000-4-5: 2014; KN 61000-4-5; KN 61000-4-5 (2008-5); KN 61000-4-5 (Annex 1-4); IEEE C62.41.1 (2002); IEEE C62.41.2 (2002); IEEE C62.25 (2002)
Conducted	IEC 61000-4-6, Ed. 2.1 (2004); EN 61000-4-6; EN 61000-4-6 (1996) + A1 (2001); IEC 61000-4-6, Ed. 2.2 (2006-05); IEC 61000-4-6, Ed. 3.0 (2008); IEC 61000-4-6, Ed. 4.0 (2013); EN 61000-4-6 (2009); EN 61000-4-6 (2014); KN 61000-4-6; KN 61000-4-6 (2008-5); KN 61000-4-6 (Annex 1-5)
Power Frequency Magnetic Field	IEC 61000-4-8 (2001) + A1 (2000); EN 61000-4-8 (2001) + A1 (2000); EN 61000-4-8 (1993) + A1 (2001); IEC 61000-4-8 (2009); EN 61000-4-8:2010; KN 61000-4-8; KN 61000-4-8 (2008-5); KN 61000-4-8 (Annex 1-6)
Voltage Dips, Short Interruptions, and Voltage Variations	IEC 61000-4-11, Ed. 2 (2004-03); EN 61000-4-11; EN 61000-4-11 (1994) + A1 (2001); EN 61000-4-11 (2004); KN 61000-4-11; KN 61000-4-11 (2008-5); KN 61000-4-11 (Annex 1-7)
<i>Product Safety</i>	
Medical Electrical Equipment	IEC 60601-1-2, Ed. 3.0 (2007); KN 60601-1-2 (2008-5); IEC 60601-1-2, Ed. 4, (2014-02); EN 60601-1-2 (2007); EN 60601-1-2 (2015)
<i>Generic/Product Family Standards and Industry Standards</i>	
Generic Standards	EN 61326-1: 2013; KN 35: 2015
Information Technology Equipment	IEC/CISPR 22 (1997); EN 55022 (1998) + A1 (2000); IEC/CISPR 22 (1993); EN 55022 (1994); IEC/CISPR 22 (1993); EN 55022 (1994) + A1 (1995) + A2 (1997); CNS 13438 (1997); IEC/CISPR 22, Ed. 4 (2003-04); EN 55022 (1998); IEC/CISPR 22, Ed. 5 (2005); EN 55022 (1998); IEC/CISPR 22, Ed. 5 (2005) + A1 (2005); EN 55022 (1998) + A1 (2000) + A2 (2003);



<u>Test Technology:</u>	<u>Test Method(s)<sup>1,2</sup>:</u>
<p><i>Generic/Product Family Standards and Industry Standards (cont'd)</i></p> <p>Information Technology Equipment (cont'd)</p>	<p>CNS 13438 (2006) (up to 6GHz); IEC/CISPR 22, Edition 5.2 (2006-03); EN 55022 (2006); EN 55022 (2006) + A1 (2007); EN 55022:2010; IEC/CISPR 22 (2008-09); AS/NZS CISPR 22 (2009); TCVN 7189:2009 (CISPR 22:2006); VCCI V-3 (2009.04, 2011.04, 2013.04, 2014.04, 2015.04) (up to 6 GHz); VCCI-CISPR 32:2016; CISPR 24 Ed 2.0 (2010-08); EN 55024 (2010); KN 24</p>
<p>Industrial, Scientific, and Medical (ISM) Equipment</p>	<p>AS/NZS CISPR 11 (2002); IEC/CISPR 11, Ed. 4.1 (2004-06); AS/NZS CISPR 11 (2004); IEC/CISPR 11, Ed. 4.1 (2004-06) + A1 (2004); EN 55011 (1998) + A1 (1999) + A2 (2002); IEC/CISPR 11 (2003); EN 55011 (1998) + A2(2002); EN 55011 (2009) + A1 (2010); IEC/CISPR 11 Ed. 5 (2009-05); CISPR 11 Ed. 5.1 (2010)</p>
<p>Measure</p>	<p>IEC 61326-1 Ed. 2.0 (2012)</p>
<p>Military/Defense</p>	<p>MIL-STD-461F Method CE101 (30 Hz to 10 kHz); MIL-STD-461F Method CE102 (10 kHz to 10 MHz); MIL-STD-461F Method CE106 (10 kHz to 40 GHz); MIL-STD-461F Method CS101 (30 Hz to 150 kHz); MIL-STD-461F Method CS106; MIL-STD-461F Method CS114 (10 kHz to 200 MHz); MIL-STD-461F Method CS116 (10 kHz to 100 MHz); MIL-STD-461F Method RE101 (30 Hz to 100 kHz); MIL-STD-461F Method RE102 (10 kHz to 18 GHz); MIL-STD-461F Method RE103 (10 kHz to 40 GHz); MIL-STD-461F Method RS101 (30 Hz to 100 kHz); MIL-STD-461F Method RS103 (2 MHz to 40 GHz)</p>

<sup>1</sup> When the date, revision or edition of a test method standard is not identified on the scope of accreditation, the laboratory is required to be using the current version within one year of the date of publication, per part C., Section 1 of A2LA R101 - *General Requirements- Accreditation of ISO-IEC 17025 Laboratories*. If a specifier/regulator imposes a different transition period, this will supersede the A2LA one-year implementation period.

<sup>2</sup> The laboratory is only accredited for testing activities outlined within the test methods listed above. Reference to any other activity within these standards, such as risk management or risk assessment, does not fall within the laboratory's accredited capabilities.

On the following types of products:

Telecommunication Equipment, Network Equipment, Industrial and Commercial Equipment, Electronic (Digital) Equipment, Medical, Aerospace, Military, Information Technology Equipment, Multimedia Equipment, Scientific Equipment

(A2LA Cert. No. 0214.43) Revised 08/30/2018



Page 3 of 4

Testing Activities Performed in Support of FCC Declaration of Conformity and Certification in Accordance with 47 Code of Federal Regulations and FCC KDB 974614, Appendix A, Table A.1<sup>3</sup>

Rule Subpart/Technology	Test Method	Maximum Frequency (MHz)
<u>Unintentional Radiators</u> Part 15B	ANSI C63.4:2014	40000
<u>Industrial, Scientific, and Medical Equipment</u> Part 18	FCC MP-5 (February 1986)	40000
<u>Intentional Radiators</u> Part 15C	ANSI C63.10:2013	40000

<sup>3</sup>Accreditation does not imply acceptance to the FCC equipment authorization program. Please see the FCC website (<https://apps.fcc.gov/oetcf/eas/>) for a listing of FCC approved laboratories.



## Accredited Laboratory

A2LA has accredited

### **NATIONAL TECHNICAL SYSTEMS (NTS) - LONGMONT** Longmont, CO

for technical competence in the field of

### Electrical Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005 *General requirements for the competence of testing and calibration laboratories*. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated 8 January 2009).



Presented this 28<sup>th</sup> day of October 2016.



President and CEO  
For the Accreditation Council  
Certificate Number 0214.43  
Valid to September 30, 2018  
Revised August 30, 2018

*For the tests to which this accreditation applies, please refer to the laboratory's Electrical Scope of Accreditation.*

**END OF REPORT**